

**F. Consent Agenda - Parks and Recreation Department
ITEM 9.**



**AGENDA REPORT
August 21, 2018**

**Acknowledge No Bids Received, Waive Procurement Process and
Permission to Execute Contract Amendment with Golf Brevard Inc. for
Replacement of Pumping Station at Spessard Holland Golf Course**

SUBJECT:

Acknowledge No Bids Received, Waive Procurement Process and Permission to Execute Contract Amendment with Golf Brevard, Inc. for Replacement of Pumping Station at Spessard Holland Golf Course - District 3

FISCAL IMPACT:

Approval of this action will result in an expenditure of \$111,229.35. Funds are available for this project in Fund 1019, Cost Center 250410, South Area Maintenance.

DEPT/OFFICE:

Parks and Recreation

REQUESTED ACTION:

It is requested the Board of County Commissioners:

- 1) Acknowledge no bids were received in response to the Invitation to Re-bid for replacement of the pumping station at Spessard Holland Golf Course
- 2) Waive the Procurement Process
- 3) Authorize the Chair to execute Contract Amendment, upon County Attorney and Risk Management approval with Golf Brevard and authorize the County Manager to execute necessary Budget Change Requests

SUMMARY EXPLANATION and BACKGROUND:

On February 19, 2018 the pumping system at the Spessard Holland Golf Course failed. A service request was submitted to Systematic Services to explore whether the pumping system could be repaired or needed to be replaced. Due to the costs associated with repair it was determined replacement of the system was necessary. IGM temporarily repaired the system until a permanent replacement was procured.

On April 10, 2018, the Board granted permission to solicit and award to the lowest responsive bidder for the replacement of the variable speed pumping system at Spessard Holland Golf Course. On July 10, 2018 the Board granted permission to reject the bids received in response to Bid #B-5-18-57 due to two (2) bidders exceeding project costs and one (1) bidder deemed non-responsive. On July 23, 2018 a subsequent invitation to bid was publically advertised and opened on August 2, 2018. No bids were received in response to this Invitation to Bid.

Golf Brevard, Inc., which will take over the management of Spessard Holland on September 1, 2018, has submitted a proposal requesting \$111,229.35 to replace the pumping station under a contract amendment to their existing contract. IGM, the current golf course maintenance contractor also submitted a proposal of \$129,407 to replace the pumping station to be completed under a task order of their expiring contract.

Waiver of the procurement process and approval of the Contract Amendment will authorize Golf Brevard to perform the necessary work to assure necessary irrigation and watering of the golf course.

ATTACHMENTS:

Description

- ▢ Proposal Wescoturf Pump Station Spessard**
- ▢ Proposal SystemeMatic Pump Station Spessard**



Tammy Rowe, Clerk to the Board, 400 South Street • P.O. Box 999, Titusville, Florida 32781-0999

Telephone: (321) 637-2001
Fax: (321) 264-6972
Tammy.Rowe@brevardclerk.us

August 22, 2018

MEMORANDUM

TO: Mary Ellen Donner, Parks and Recreation Director

RE: Item F.9., Acknowledge No Bids Received, Waive Procurement Process, and Permission to Execute Contract Amendment with Golf Brevard Inc. for Replacement of Pumping Station at Spessard Holland Golf Course

The Board of County Commissioners, in regular session on August 21, 2018, acknowledged no bids were received in response to the Invitation to Re-bid for replacement of the pumping station at Spessard Holland Golf Course; waived the procurement process; authorized the Chair to execute Contract Amendment, upon County Attorney and Risk Management approval with Golf Brevard; and authorized the County Manager to execute any necessary budget change requests.

Your continued cooperation is always appreciated.

Sincerely,

BOARD OF COUNTY COMMISSIONERS
SCOTT ELLIS, CLERK

Tammy Rowe

Tammy Rowe, Deputy Clerk

/kp

cc: Finance
Budget

Deborah Thomas

From: Renninger, Melissa L <melissa.renninger@brevardfl.gov>
Sent: Monday, August 20, 2018 4:17 PM
To: Deborah Thomas
Subject: RE: ITEM F9 RE SPESSARD HOLLAND GOLF

Hey,

I check with Jim Liesenfelt and nothing needs signed or initialed at this time.

Matt Soss is still working an agreement that will need signed/attested at a later date.

Thanks so much for checking!

Melissa Renninger

Contract Administrator
Parks and Recreation Department
2725 Judge Fran Jamieson Way, Bldg B
Viera, FL 32940

Phone (321) 633-2046 (x32)

Email melissa.renninger@brevardfl.gov

Web www.brevardparks.com



From: Deborah Thomas [mailto:deborah.thomas@brevardclerk.us]
Sent: Monday, August 20, 2018 3:45 PM
To: Renninger, Melissa L
Subject: ITEM F9 RE SPESSARD HOLLAND GOLF

Hi Melissa:

How are you?

Parks and Recreation has Item F9 on the Agenda for tomorrow's Board meeting.

Are there any signatures required on this Item?

There are initials required on the bottom of each page and then an "Accepted" signature required on the last page.

Does the Chair need to sign this?

First Amendment to Agreement

THIS AGREEMENT made and entered into this 21st day of August 2018 by and between the Board of County Commissioners of Brevard County, Florida, a political subdivision of the State of Florida (hereinafter referred to as the "COUNTY") and Golf Brevard, Inc., a Florida Not for Profit Corporation (hereinafter referred to as "GOLF BREVARD").

WHEREAS, the parties hereto have previously entered into an Agreement on April 24, 2018 (attached hereto and incorporated herein as Attachment "A" and said agreement shall be referred to hereafter as the "Agreement"); and

WHEREAS, the parties hereto desire to amend the Agreement to provide for the installation of a variable speed pumping station at Spessard Holland Golf Course; and

WHEREAS, the GOLF BREVARD has provided a written estimate of \$111,229.35 for the complete replacement and installation of the variable speed pumping station at Spessard Holland Golf Course.

NOW, THEREFORE, in consideration of the premises and mutual covenants herein contained, the parties hereby agree, as follows:

I. RECITALS

The above recitals are true and correct and are incorporated into this Agreement by this reference.

II. AMENDMENT TO SECTION 18 OF THE AGREEMENT.

Section 18 of the Agreement shall be amended to include a Section 18.12 which shall consist of the following language:

"GOLF BREVARD shall be responsible for the complete replacement of the existing Spessard Holland 1,100 gallon pumping system, valves, pumps/motors, and controls of the variable speed pumping station and all other appurtenances needed for the pumping station to serve its intended purpose (collectively referred to as the "pumping station). The pumping station being provided by GOLF BREVARD shall be of like quality to the original pumping station at the golf course, and shall be fit for the purpose of assuring complete watering and irrigation of the Spessard Holland golf course. At a minimum, the pumping station and appurtenances shall meet all the specifications outlined in the proposal attached to the first Amendment to Agreement and incorporated herein by reference and therein as Attachment "B." All warranties provided by the manufacturer shall be assigned to COUNTY.

PKRECS-ADMIN
SEP272018 12:53

SCOPE OF SERVICE

Task 1 – Site Visit: In general, GOLF BREVARD will arrange for and attend a site visit with COUNTY staff to (a) observe site conditions, and (b) refine the extent of the proposed

improvements as may be warranted based upon site conditions. GOLF BREVARD will observe and document site conditions that warrant repair or replacement. GOLF BREVARD will confer with the COUNTY regarding the results of the site visit and any revisions warranted to the conceptual design as identified in the permit applications filed by the COUNTY.

Task 2 – Installation: Upon COUNTY acceptance, the GOLF BREVARD will purchase and install a new pumping station and all required appurtenances. The final specifications for the new pumping station shall be submitted to COUNTY for COUNTY’S written approval prior to purchase by GOLF BREVARD.

Time is of the essence with respect to the performance of this work. The work to be shall be commenced upon execution of the Amendment to the Agreement with completion by November 1, 2018.

COMPENSATION

For the completion of Tasks 1 and 2, GOLF BREVARD shall be provided a flat fee of \$111,229.35 (hereinafter the “Flat Fee Amount”) as total monies due to GOLF BREVARD for the scope of services provided herein. Fifty percent (50%) of the Flat Fee Amount (\$55,614.68) will be paid in advance of any work commencing. GOLF BREVARD shall invoice the COUNTY for the initial \$55,614.68 and shall provide a second invoice for the remaining balance of \$55,614.67. The second invoice for the unpaid portion of the Flat Fee Amount shall be submitted to the County upon:

1. Written notification to COUNTY from GOLF BREVARD that delivery of pumping station to GOLF BREVARD at Spessard Holland golf course is imminent; and
2. Receipt by COUNTY of written certification from pumping station manufacturer to GOLF BREVARD that the pumping station is 80% constructed and meets the county-approved final specifications.

No costs in excess of the Flat Fee Amount shall be incurred without consultation with the COUNTY and the COUNTY’S agreement in writing to said additional costs.”

III. OTHER TERMS AND CONDITIONS

All of the terms and conditions of the Agreement (attached hereto as Attachment “A”) shall apply as if fully set out herein unless such terms and conditions are specifically superseded by the terms and conditions of this Amendment. This Amendment is not intended by the parties to be, and shall not be construed to be, a novation of the Agreement.


IV. EFFECTIVE DATE AND AUTHORIZATION TO PROCEED

This Amendment shall be effective upon the date this Amendment is signed by both parties.

IN WITNESS WHEREOF, the parties hereto set their hands and seals.

ATTEST:

BOARD OF COUNTY COMMISSIONERS
Page 2 of 3



OF BREVARD COUNTY, FLORIDA

Scott Ellis, Clerk of Court

By: Rita Pritchett, Chair Date

As approved by the Board on 8/21/18.

Reviewed for legal form and content:

Matthew Soss

Matthew Soss, Assistant County Attorney

WITNESSES:

GOLF BREVARD, INC.

Carol Becker
Tommy Becker

By: Carol Becker
105, Chair Date
09/17/2018

(CORPORATE SEAL)



2101 Cantu Court
Sarasota FL 34232
941.377.6777 • 800.486.8873
Fax 941.467.6889

300 Technology Park
Lake Mary FL 32746
407.333.3600
Fax 407.333.8245

7037-37 Commonwealth Avenue
Jacksonville, FL 32220
904.783.0600
Fax 904.783.3835

WescoTurf.com

PROPOSAL Variable Speed Pump Station

Date: July 27, 2018

Project: Spessard Holland

To: Wesco Turf

Quotation Number:
MCI02092018SA

Quoted by: Emily Lewis

Requirements: 1600 GPM at 100 PSI at station discharge

Supply Power: 460/3/60

Pumpset: 9'-0" (Unconfirmed)

Wetwell Depth: 10'-0" (Unconfirmed)

Wetwell Size: 60" (Unconfirmed)

PROPOSAL SCOPE

1 Ea. MCI UL Listed QCZJ Packaged Pump Station
Part Number PPS-N-VT2-1600-100-SV-P-46-3-6

UL Listed Pump Station complete with monolithic skid, sch40 steel manifolds, isolation valves, vertical turbine pumps/motors, check valves and discharge flow meter. Standard MPC controls with single VFD drive and alternating contactors so each main motor may run XL or VFD. Built under ISO9001:2008 certification.

MPC Standard Controls

- UL 508a Listed Control Panel
- Short Circuit Current Rating 100 ka
- NEMA 3R Enclosure
 - 3 Point Latch
 - Carbon Steel w/ Powder Coat Finish
- UL Listed heat exchanger
- 200-amp Main Fused Disconnect

Initials _____

MCI Quotation MCI02022018SA



2101 Cantu Court
Sarasota FL 34232
941.377.6777 • 800.486.8873
Fax 941.487.8859

300 Technology Park
Lake Mary FL 32746
407.333.3600
Fax 407.333.9245

7037-37 Commonwealth Avenue
Jacksonville, FL 32220
904.783.0500
Fax 904.783.3835

WescoTurf.com

- Type 1 Surge Protection w/status indicators
- Incoming Line Phase Monitor w/primary fusing
- PM Pump 5 HP
 - Class J fuses/block per contactor
 - AB Contactor w/1 AB SS OL per motor
- 2 Ea. Main Pump 60 HP
 - 1 Ea. Danfoss Aqua Drive w/high speed JKS fuse protection
 - 3 ½% DC Input Link Reactor
 - Door Mounted Keypad
 - 60 HP 6 Year Warranty on Danfoss VFD which includes coverage against damages from momentary line or load anomalies such as lightning strikes.
 - Class J fuses/block per contactor
 - AB Interlocked Contactors w/1 AB SS OL per main motor
- AB compactlogix PLC Platform
- AB 10" Panelview +7 Color HMI
- Inhand Network Switch with Modem
- AB DC Power Supply
- AB "Full Size" 30 mm N4 Door Devices
 - Green Illuminated Switch per pump
 - System Switches: System Control, Low Discharge, VSD Bypass, PLC Bypass, Speed Pot and Red Illuminated Fault Push Button
- GFCI Outlet
- Control Power Transformer w/primary/secondary fusing
- Flow Signal Input: Pulse
- Lake Level Controls
 - HOA Selector Switch
 - PNR & Probes
- Fertigation Relay
- Safeties:
 - Low level shutdown
 - Low discharge pressure shutdown
 - High discharge pressure shutdown w/auto restart
 - VSD fault with auto restart
 - Solid State Overload shutdown per motor
 - Phase Failure, Imbalance and low voltage protection
- Operation Features
 - Lamp Test Function
 - Automatic alternation of pumps based on least run time
 - Intelligent Slow Ramp feature for automatic line fill
 - VFD Bypass
- 10" Color Touch screen interface
 - 3 Year Flow Total Logging Year/Month/Day

Initials _____

MCI Quotation MCI02022018SA



2101 Cantu Court
Sarasota FL 34232
941.377.6777 • 800.486.8873
Fax 941.487.6889

300 Technology Park
Lake Mary Fl. 32746
407.333.3600
Fax 407.333.9246

7037-37 Commonwealth Avenue
Jacksonville, FL 32220
904.783.0500
Fax 904.783.5835

WescoTurf.com

- Pump Run Times
- Event Log
- Flow and Station Trending
- Assignable I/O
- **MPC Remote Cell Monitoring w/1 Year Activation 250 MB Data Plan Limit per month**
- **nSite, MCI's Cloud Based Solution NO SUBSCRIPTION FEE**
 - Scheduled monthly email with flow report in Excel format
 - Access to one full year of pressure, flow, alarms and event data
- **nAlert**
 - Manage maintenance due dates for all aspects of maintenance on your pumping station.
 - Warning light, display message and email alert when due.
 - Monitor and report irregular operation of irrigation system, pump system and filter system.

Instrumentation

- SS Wika Pressure Transmitter 0-250 PSIG
- DI220B Flow sensor
- Durachoice 4" Pressure Gauge w/isolation ball valve

Pumps

- 2 Ea. 60 HP Goulds Model 12CLC-4 Vertical Turbine Pumps, 9' Pump Length (Unconfirmed), each rated for 800 GPM @ 250' TDH including station losses. To include;
 - Cast Iron Bowls w/316 Investment cast SS Impellers
 - 416SS Stainless Steel Shafting
 - 416SS impeller collets
 - Water lubricated line shaft bearings 5 ft. spacing
 - High pressure stuffing box
 - Fabricated Steel Discharge Heads
 - Threaded Carbon Steel Column pipe, Standard wall thickness, 5' ft. sections.
 - Stainless Steel Pump Strainer
 - 60 HP, 1800 RPM, 460/3/60, premium efficient, Vertical Hollow Shaft Motors with motor space heaters and non-reverse ratchets.
- 1 Ea., PM, 5 HP Submersible SS Pump & Motor. With 2" pump head and discharge threaded column pipe.

Isolation Valves

- 8" Station Discharge isolation butterfly valve w/gear operator, SS disc and EPDM elastomers, fusion bonded body.
- 2" and 6" Anvil Gruvlok Pump Isolation Valves with lever actuator.
- 2" and 6" Pump silent wafer check valves coated with fusion bonded epoxy and SS disc.
- 316SS threaded ball valves, 1.5" and below

Initials _____

MCI Quotation MCI02022018SA



2191 Cantu Court
 Sarasota FL 34232
 941.377.6777 • 888.486.8673
 Fax 941.487.6889

300 Technology Park
 Lake Mary FL 32746
 407.333.3600
 Fax 407.333.9246

7037-37 Commonwealth Avenue
 Jacksonville, FL 32229
 904.783.0500
 Fax 904.783.3835

WescoTurf.com

Relief Valves Standard Fusion Bonded Epoxy Inside/Out w/ Bronze Trim

- ClaVal 50-01 4" Station pressure relief valve with bronze trim, piped to wetwell with Discharge isolation butterfly valve w/lever operator, SS disc and EPDM elastomers, fusion bonded body.

Skid

- 6" Structural skid system
- Integral Wet Well Access Hatch(s)
- Steel Grit blasting to SSPC-10 of station structural steel.
- PPG Enviracryl Zinc epoxy powder coat Primer
- Poly Powder coated non-skid paint system

Piping

- Steel Grit blasting to SSPC-6 of station piping.
- NSF61 fusion bonded epoxy powder coating of all piping 2" and above internal and externally.
- Piping 2" and below to be 304SS.
- Hose Bibb connection

On Site set supervision, Start up and training not included in pricing.

PRICE: \$97,729.35
Includes freight

FOB: Dallas, Texas

Lead Time: 8-10 weeks following approved drawings

Optional Equipment: (Not Included in Pricing)

- Adder to change from WP1 Motors to TEFC Motors (Price per Motor) **\$2,523.91**
- Adder for Fertigation Equipment:
 - Single Pump 12.3 GPH Injection System **\$5,466.30**
 - Single Pump 30 GPH Injection System **\$6,918.89**
 - Single Pump 85 GPH Injection System **\$7,576.09**
 - 1050 Gallon Cone Bottom Storage Tank **\$2,190.22**

Additional Warranty items

- **Warranty excludes crane if needed**
- **6-year warranty on Variable frequency drive (Includes lightning damage coverage and labor to replace)**
- **6 Year Warranty on ALL COMPONENTS IN ELECTRICAL PANEL, Inclusive of power related damage such as lightning. Includes parts only.**
- **6-year warranty on Station**

Initials _____

MCI Quotation MCI02022018SA



2101 Cantu Court
Sarasota FL 34232
941.377.6777 • 800.486.8673
Fax 941.487.6385

300 Technology Park
Lake Mary FL 32746
407.333.3800
Fax 407.333.9246

7937.37 Commonwealth Avenue
Jacksonville, FL 32226
904.783.6500
Fax 904.783.3835

WescoTurf.com

Pricing does NOT include any installation, crane charges, taxes unless otherwise noted.

TERMS AND CONDITIONS OF SALE

All sales by and purchases from MOTOR CONTROLS INC., (Seller) are governed by the following terms and conditions:

1. All purchases and credits occurring after the closing date of a month will appear on the periodic statement for the next month. Payment shall be made to the Seller in U.S. currency at its offices in Dallas, Dallas County, Texas.
2. All purchase orders are subject to acceptance at Motor Controls Inc, Dallas, Texas. The following terms shall govern unless superseded by revised or negotiated terms listed in the proposal body. Receipt of Production deposit, verification of acceptable credit and confirmation of design are required before production. On domestic orders of \$100,000 or less, a 20% production deposit is required to initiate the order with the balance due next 30 days from date of final invoice. Orders over \$100,000 shall require a 40% production deposit. For international orders, either an Irrevocable Letter of Credit (ILC) drawn on a U.S. Bank, with all costs of the ILC borne by the purchaser, is required for the full amount of purchase at time of order, or a 100% cash deposit with order.
3. In all cases if customer is unable to accept delivery once fabrication, assembly and testing are completed at the factory MCI shall invoice the total balance due. Customer shall agree to coordinate with MCI for storage arrangements and/or additional storage charges as deemed appropriate and necessary.
4. Late fee of 1.5% per month will be added to any balance due after thirty (30) days from the date of invoice. All payments and/or credits are applied to the outstanding balance before computing a finance charge.
5. All Orders shall be F.O.B. Dallas, Texas.
6. State, city and local taxes are excluded from the contract price unless otherwise noted. Sales tax will be invoiced on the contract price unless written exemption is provided.
7. Prices valid for 60 days from date of proposal unless
Otherwise noted
8. Orders regularly entered, whether verbal or written, can only be cancelled in writing by the Buyer upon terms that will compensate the Seller against loss. Any additional paperwork furnished at the Buyer's request, such as sketches, drawings and specification sheets will be charged at Seller's cost.
9. Any claim for defects, damages or shortages of an order delivered must be made by the Buyer in writing and delivered to Seller within a period of ten (10) days after delivery. Failure to make such claim within the specified time constitutes an acceptance and admission that the order fully complies with the terms, conditions and specifications required. The Seller's liability shall be limited to the stated selling price of any defective goods and shall in no event include special or consequential damages, including profits (or profits lost) or loss of use. Seller shall not be liable to buyer or any other person for any liability, loss, or damage caused or alleged to be caused, directly or indirectly, by the pumping package. Seller makes no warranty, whether express or implied, with respect to fitness for a particular purpose or merchantability of the pumping package or component
10. The Buyer bears the risk of loss of or damage to or destruction of the goods from the time of delivery. The Seller retains title to the goods until the Buyer pays the entire purchase price as specified plus any interest thereon. If requested by Seller, Buyer shall execute a security agreement and financing statement evidencing Seller's security interest in the goods delivered to Buyer
11. If the credit of Buyer in the judgment of the Seller becomes impaired at any time, the Seller has the right to require payment in advance before making further shipments, and to demand immediate performance of the Buyer of all obligations imposed upon him by this agreement.
12. If there is any breach of or default under this agreement and if the same is placed in the hands of an attorney for collection, or if collected by lawsuit or through the probate or bankruptcy court, or if any action of foreclosure be had hereunder, Buyer shall be liable for reasonable attorney's fees incurred by

Initials _____

MCI Quotation MCI02022018SA



2401 Cantu Court
Sarasota FL 34232
941.377.6777 • 800.486.8879
Fax 941.487.6688

360 Technology Park
Lake Mary FL 32746
407.333.3600
Fax 407.333.0248

7037-37 Commonwealth Avenue
Jacksonville, FL 32220
904.783.0500
Fax 904.783.3625

WescoTurf.com

the Seller. In the event of default by Buyer, Seller may immediately proceed to enforce payment of Buyer's obligation and exercise all the rights and remedies provided by the Business and Commerce Code of the State of Texas, or the Uniform Commercial Code, as well as any other rights and remedies afforded to Seller by law. Should Buyer be in default, Seller may require Buyer to return all goods previously delivered to Buyer by Seller, and any subsequent expenses for retaking, holding, preparing for sale, and reselling of such goods shall be at Buyer's expense. Funds realized from such resale shall be credited to Buyer's unpaid account.

13. The Seller, or any credit bureau or investigating agency employed by the Seller, is hereby authorized to investigate the references herein listed or statements or other data obtained from the Buyer or from any other persons pertaining to the Buyer's credit or financial responsibility. The Buyer has read and understands the foregoing terms and conditions of this application for credit and has signed the same as an indication of intent to enter into an agreement with Seller for the future purchase of goods and services from time to time. The Buyer also understands that upon acceptance of this application by the Seller, this document constitutes an agreement between the Buyer and the Seller for payment of debts owed to the Seller in return for the delivery of goods ordered or performance of services requested by Buyer.
14. The terms herein contained shall be governed by the statutes of the State of Texas, and specifically the Business and Commerce Code of the State of Texas and the Uniform Commercial Code. In the event that any account owing by Buyer to Seller becomes delinquent, and legal proceedings are instituted for collection of said account or indebtedness, such legal proceedings may be instituted and prosecuted against Buyer and its guarantors, if any, in any Court in Dallas County, Texas, and the undersigned expressly agrees that venue for such proceeding shall be in Dallas County, Texas, even if the principal offices of the Buyer are located in another county within this state or outside of this state.
15. SELLER DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, REGARDING THE MERCHANTABILITY OF THE GOODS DELIVERED TO BUYER NOR THE FITNESS OF SUCH GOODS FOR A PARTICULAR USE UNLESS A WRITTEN WARRANTY IS GIVEN TO BUYER BY SELLER AT TIME OF DELIVERY.
16. Seller warrants that the water pumping system or components will be free of defects in Materials and workmanship for 2 years from date of authorized start-up but not later than 27 months from date of invoice;

Provided that all installation and operation responsibilities have been properly performed and documented. Seller will provide a replacement part or component during the warranty life. Repairs done at Seller expense must be pre-authorized. Upon request, Seller will provide advice for troubleshooting the system.

This proposal contains equipment that may require costly means to remove or replace based on site conditions. Seller will not accept liability for costs associated with the removal or replacement of equipment in difficult to access locations. This includes but is not limited to the use of large cranes, diving services, barges, helicopters, or other unusual requirements.

Default of any agreement with Seller or;

- a. The misuse, abuse of the pumping package outside its intended use.
 - b. Failure to perform required maintenance service.
 - c. Pumping water not suitable for irrigation.
 - d. Exposure to electrolysis erosion.
 - e. Water salinity in excess of 2000 parts per million.
 - f. Water from a reverse osmosis plant without countermeasures in place.
 - g. Water with a Langelier Index less than -0.5 and greater than +1.5
 - h. Presence of destructive gaseous or chemical solutions in our around the packaged system.
17. The terms contained herein may be modified only by written agreement signed by Buyer and an officer of Seller, MOTOR CONTROLS INC.

Initials _____

MCI Quotation MCI02022018SA



2101 Cantu Court
Sarasota FL 34232
941.377.6777 • 800.486.8873
Fax 941.487.6889

300 Technology Park
Lake Mary FL 32746
407.333.3600
Fax 407.333.9246

7037-37 Commonwealth Avenue
Jacksonville, FL 32220
904.783.0500
Fax 904.783.3835

WescoTurf.com

Is this sale Taxable? (Circle one) YES NO

(If non-taxable please provide tax exempt certificate for the "ship-to" state)
Please fill out fields below and return all pages.

Accepted for Buyer: _____

Date: _____ Total Value with options: _____

Requested ship date: _____

Ship to Address: _____

Street address: _____

County _____ State _____ Zip _____

Contact Name: _____

Phone & Fax: _____ / _____

Email: _____

Initials _____

MCI Quotation MCI02022018SA

#9
11



**SYSTEMATIC
SERVICES, INC.**
East Coast Division

Contact: Mike Yurigan	Date: 8/15/2018
Job Name: Spessard Holland Golf Club	Quote Number: E201808009
Address: 2374 Oak Street	Phone Number: 407 257-3649
City, State, Zip: Melbourne, FL 32951	Fax Number:

REFERENCE: Pump Station Replacement

DESCRIPTION	COST
<p>Provide crane and labor required to offload new pump station upon arrival. Set station in temporary staging area provided by customer until ready for installation.</p> <p>Provide Crane and technicians required to: Remove existing motors, pumps, control panel.</p> <p>Install the new pump station skid, pumps, and motors.</p> <p>Connect electrically and mechanically to existing electrical service and discharge piping.</p>	
Total	\$ 13,500.00

Not included in above:

- μ Repairs to other components found to be defective during the installation of above.
- μ Additional work resulting from customer induced on site delays or requests.

Notes:

- μ All prices are good for sixty (60) days.
- μ Please allow 1 week for delivery after receipt of order confirmation and purchase order.
- μ This is a per location quotation. We will accept one or more confirmation(s) at the customer's convenience, with associated purchase order(s).

Terms:

- μ All past due accounts (over 30 days) are subject to 1.5% monthly finance charge.
- μ Due upon receipt of associated invoices.

Signing below will confirm the acceptance of the above proposal with all terms and conditions as noted. Once accepted, please mail this document to the address below with your purchase order and production deposit. Thank you for choosing Systematic Services to serve your pumping station needs.

Presented by: _____ **Date:** _____
 Tony Crocco

Accepted by: _____ **Date:** _____